



15 Oct 2019

ECM Review Panel
REVIEW OF EARTH CONTROL MEASURES PLAN AND SERVICES PROVIDED BY QECP

The 19th quarterly review session on 5 QECP ECM plans was conducted on 4 Oct 2019.

Under this session, 5 QECPs were present to share their ECM plan and follow up supervision.

- 2 The key findings from this session are similar to earlier review sessions, in particular:
- (a) QECP should provide clear description of the construction works involved in the submission especially for projects involving phase constructions and multiple ECM submissions;
 - (b) QECP shall ensure only relevant information are submitted, and first time submission are exhaustive, and the drawings are comprehensive for contractor site implementation.
 - (c) QECP shall check through design carried out by their engineers and ensure compliance with Code of Practice for surface Water drainage and ECM submission checklist before making ECM submissions;
 - (d) QECP shall regularly inspect the site to ensure effective implementation of ECM on site and enhancement to the ECM design are carried out timely

3 The review panel would also like to recognize commendable ECM submission by Er Chua Cheong Hwee who presented ECM submission demonstrating well thought through ECM design taking into contractor's construction schedule and available resources.

Please feel free to contact Victor Tham [victor.tham@iesnet.org.sg] at 64695000 for clarifications.